FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15

Date: 22-01-2015

TEST REPORT ON WET MIX MACADAM MIX
(GRADATION TEST)

Sub: To conduct Gradation test on Wet Mix Macadam (WMM) Mix.
{Project*: Improvements and asphalting to HMT5th Block roads in Ward No 09}in Vidyaranypaura sub division}.
Ref.: Letter No. Testing/BUB/2014-15, dated 20-01-2015
Name of the Agency/Contractor* : Mr. C.Shivaraj, Contractor,BBMP, Bangalore.
Report required for* : Assistant Executive Engineer,
Vidyaranypaura Sub-Division, BBMP, Bangalore.

TEST RESULTS

1. Gradation Test:
TABLE 1.1

Sieve Size mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Specified Limits as per MoRTH Specifications, IV Revision-2001
53	100.00	100
45	97.10	95-100
26.5	---	-
22.4	75.60	60-80
11.2	55.20	40-60
4.750	37.00	25-40
2.360	18.00	15-30
0.600	17.60	8--22
0.075	3.00	0--8

*As Furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

22/01/2015
Dr. MANJESH .L
ME (Civil Engg). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15

Date: 27-01-2015

TEST REPORT ON BITUMINOUS MIXES
(BITUMEN EXTRACTION TEST & GRADATION TEST)

Sub: Testing of Bitumen Premix Sample (Semi Dense Bituminous Concrete-SDBC). {Project*: Improvements and asphalting to HMT 5th Block roads in Ward No 09}in Vidyaranypaura sub division}.

Ref.: Letter No. Testing/BUB/2014-15, dated 24-01-2015

Name of the Agency/Contractor* : Mr. C.Shivaraj, Contractor,BBMP, Bangalore.

Report required for* : Assistant Executive Engineer,
Vidyaranypaura Sub-Division, BBMP, Bangalore.

TEST RESULTS :

5. The bitumen content obtained after subjecting the sample for Bitumen Extraction test = **5.12** %
6. **Gradation Test** :

Sieve Size, mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Gradation requirement as per Table 500-15 of MORTH Specfications-2001 (Grading – 2)
13.2	**100.00**	100
9.5	**96.40**	90—100
4.75	**46.10**	35—51
2.36	**28.30**	24—39
1.18	**18.70**	15—30
0.3	**12.00**	09—19
0.075	**4.80**	03—08

*As Furnished by Client.

The Results relate only to the items tested.

AE-9

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg .). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com